

1

2

3

4

5

6

A

B

C

D

E

F

G

H

项目

库

文件名

裁切线

PRODUCT FICHE									
Trade Mark					Carrier				
Model: Indoor					42QHG018D8SUD				
Model: Outdoor					38QHG018D8SUD				
Sound power level at standard rating conditions (Indoor/Outdoor) [dB(A)]					58/65				
Refrigerant type					R32				
GWP <sup>[1]</sup>					675				
Charge amount <sup>[1]</sup> [kg]					1.10				
CO2 equivalent <sup>[1]</sup> [tonnes]					0.74				
SEER					7.0				
Energy efficiency class in cooling					A++				
Annual electricity consumption in cooling <sup>[2]</sup> [kWh/a]					264				
Design load in cooling mode (Pdesign) [kW]					5.28				
SCOP (average heating season) [W/W]					4.0				
Energy efficiency class in heating (average season)					A+				
Annual electricity consumption in heating (average season) <sup>[2]</sup> [kWh/a]					1435				
Design load in heating mode (Pdesign) [kW]					4.10				
Declared capacity at reference design condition (Average) [kW]					3.107				
Back up heating capacity at reference design condition (Average) [kW]					0.993				
SCOP (Warmer) [W/W]					5.1				
Energy efficiency class in heating (Warmer)					A+++				
Annual electricity consumption in heating (Warmer) <sup>[2]</sup> [kWh/a]					1235				
Design load in heating mode (Pdesign) (Warmer) [kW]					4.5				
Declared capacity at reference design condition (Warmer) [kW]					4.500				
Back up heating capacity at reference design condition (Warmer) [kW]					0.000				
[1] Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to [675]. This means that if 1kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be [675] times higher than 1kg of CO2 , over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional									
Contains fluourinated greenhouse gases.									
Importer: AHI Carrier S.E. Europe Single Member S.A. Address: 18, Kifissou Avenue, 104 42 Athens, Attiki Greece									
Manufacturer: Century Carrier Residential Air-conditioning Equipment Co., Ltd. Address:Room 505, 5/F, Tower 3, Enterprise Square, 9 sheung Yuet Road,Kowloon Bay, Kowloon, Hong Kong									
[2] Energy consumption "XYZ" kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.									
Note: Please check the model information above according to the model name on the nameplate.									

技术要求(版本号 E，2017-03)

1. 此为客牌 “” 产品信息卡。

2. 产品信息卡印刷颜色为黑色。

3. 该信息卡的幅面大小为：A4, 并在背面右下角空白处印刷物料编码。

4. 适用于客牌 “” 机型。

5. 产品应符合QMK-J036. 1010《产品说明书技术条件》的有关要求。

6. 有RoHS指令要求的物料应符合QMK-J000. 1002《产品中限制使用有害物质的技术标准》。

7. 有REACH要求的物料应符合QMK-J000. 1008《REACH法规要求技术标准》。

Technical requirements(Ver. E,2017-3)

1. This manual(or similar material) is \_\_\_brand, which is to change the basic manual's trade mark, model and data.  
(Or: providing edition to new customer )

2. The front page and inside page trade mark are dimensioned in the drawing above(or similar material) , the color is Pantone:  
(undimensioned font and pattern printing color is black)

3. The manual's dimension is:(directly list the actual dimension width \* hight,common occasion is A4)

4. This manual is available to the \_\_\_brand's \_\_\_\_\_unit.

5. Finished manuals shall comply with the relevant requirements QMK-J036.1010 technical requirementsfor Product Manual.

6. Materials subject to RoHS shall comply with QMK-J000.1002 Technical Standard for Restricted Hazardous Substance in the Products of MIDEA.

7.Materials subject to REACH shall comply with QMK-J000.1008 Technical Standard for REACH of MIDEA.

16122000A80495

						CARRIER-EU-KFR50W/BP3N8-X301(RD0)-GW(GA)-0303 (38QHG018D8SUD,内机42QHG018D8SUD ,希腊方向) (客牌物料)				
						产品信息卡				材料 铜版纸157g/m <sup>2</sup>
标记	处数	更改文件号	签 字	日 期						
绘 图	潘继宇	审 核			图 样 标 记		重 量	比 例		
设 计	潘继宇	标 准 化				K		1:1		
校 对		审 定			共 1 页		第 1 页			
会 签		日 期	2025. 1. 15							

1

2

3

4

5

6